



30 Rhodes Avenue
Oranjesig
Bloemfontein
9301

www.centlec.co.za

[@centlec](#) [@centlecutility](#)

REGIONAL SERVICES – BOTSHABELO AND THABA NCHU

INTERRUPTION OF POWER SUPPLY

RESIDENTS OF BOTSHABELO

STREET NAMES: SECTION L – Sectionalizer 2352L and 1905 L

Please note that the electricity supply to your premises will be interrupted from **09h00 until 16h00 on 6 February 2024**, alternately from **09h00 until 16h00 on the 13 February 2024**

IMPORTANT NOTICE:

1. The power may be restored without warning at any time during the shutdown period, and all installation must therefore be treated as live and dangerous.
2. Should your power not be interrupted within 1 hour of the scheduled starting time, please ignore this notice, as the scheduled maintenance has been postponed due to unforeseen circumstances. You will receive another notice in due course.

The shutdown is necessary for construction and / or maintenance upgrades on the network.

We apologize for the inconvenience caused as a result of the interruption.

For any enquiries, please contact our 24 hours Call Centre at 051 409 2345/086 007 6937.

Authorized by: 
Mr. LJ Mojaje
Executive Manager: Engineering Wires

OPERATING INSTRUCTION FORM				Operating NR			
OPERATION DATE:		06 '02' 2024		SWITCHING CHECKED BY			
CONTROL OFFICER:		S. HEINRICH		CHECKED BY NAME (PRINTED)		R. Motshure	
REQUEST FROM:		TOWN:		CHECKED SIGNATURE			
DISTRIBUTION CENTRE:		SUB T		[Signature]			
SWITCHING DETAILS:		MAINTENANCE					
TYPE SWITCHING		Isolate & Re-commission	VOLTAJE	11		KV	
RE-COMMISSIONING ONLY							
WHAT IS THE PERMIT NO:							
IS THE SIGNED PERMIT WITH THE ELECTRICIAN (YES/NO): <input type="checkbox"/>							
IF NOT, NAME THE PERSON IN POSSESSION OF THE PERMIT:							
IS THE CLEARANCE PART OF THE PERMIT SIGNED OFF BY ALL PEOPLE CONCERNED: <input type="checkbox"/>							
PERIOD	PORT OF OPERATING	OPERATION TO BE PERFORMED	LOCK NUMBER	GIVEN	RECEIVED	TIME TAKEN	
		ISOLATION					
		OPEN SECTIONALIZER 2352L AND 1905H, TEST THE LINES, IF DEAD HANG PORTABLE EARTHS ALL THIS THROUGH CONTROL INSTRUCTIONS					09:00
		RE-COMMISSION					
		REMOVE ALL EARTHS FROM THE LINE, MAKE SURE EVERYONE IS OFF THE LINE, CLOSE 2352L AND 1905H SECTIONALIZERS, ALL THIS THROUGH CONTROL INSTRUCTIONS					16:00

OPERATION CARRIED OUT BY:	DATE SWITCHED:	TOTAL OPERATING TIME:
DECLARE HEREBY THAT THE ABOVE MENTIONED INSTRUCTIONS WAS PERFORMED ACCORDINGLY		TIME COMPLETED
ISOLATION Done by Name:	NAME (PRINTED)	IF THE ABOVE WOULD BE COMPLETED ACCORDINGLY TO OPERATION INSTRUCTIONS <input type="checkbox"/>
RE-COMMISSIONING Done by Name:	NAME (PRINTED)	SIGNATURE
		SIGNATURE