



30 Rhodes Avenue
Oranjesig
Bloemfontein
9301

www.centlec.co.za

@centlec @centlecutility

INFRASTRUCTURE & SUPPORT SERVICES

INTERRUPTION OF POWER SUPPLY

RESIDENTS OF: BLOEMSPRUIT

AREAS AFFECTED: SHANNON, ARCATA & PINE HEAVEN

FEEDER: RECLOSER 1 – GRASSLAND SUBSTATION

Please note that the electricity supply to your premises will be interrupted from **09H00 until 16H00 on the 21st of December 2023**, alternately from **09H00 until 16H00 on the 28th of December 2023**.

IMPORTANT NOTICE:

1. The power may be restored without warning at any time during the shutdown period, and all installation must therefore be treated as live and dangerous.
2. Should your power not be interrupted within 1 hour of the scheduled starting time, please ignore this notice, as the scheduled maintenance has been postponed due to unforeseen circumstances. You will receive another notice in due course.

The shutdown is necessary for construction and / or maintenance upgrades on the network.

We apologize for the inconvenience caused as a result of the interruption.

For any enquiries, please contact our 24 hours Call Centre at 051 409 2345/086 007 6937.

Authorized by: 
Mr. Justice Mojaje
Executive Manager: Engineering Wires

Directors: MC Mokitlane (Chairperson), MB Mfanta (Deputy Chairperson), G Mohanoe (NED)
DR Barlow (NED), NT Baloyi (NED), MA Mopeli (NED), MS Sekoboto (CEO)

Switching Report (#7509)

Operating Instructions Form				Operating No:	
Operation Date	12/21/2023 8:38 AM			Switching Checked By:	
Control Officer	tsakie			Checked By Name: (Printed)	
Request From	Heinrich Spangenberg				
Town/City	Bloemfontein			Checked Signature:	
Dist Centre	Elite				
Switching Details	ARCATA SUB				
Type of Switching	RECOMMISSIONING	Voltage	11 kV		
RECOMMISSIONING ONLY					
What is the permit nr?					
Is the Permit with the responsible person (Yes/No)?					YES / NO
Is the clearance port of the permit signed off by all people concerned (Yes/No)?					YES / NO
Name of the person in possession of the permit:					
Has all earthing equipment been Removed (Yes/No)?					YES / NO
Confirmed all personnel are save (Yes/No)?					YES / NO

Person Switching	Point of Operating	Operating to be performed:	Lock #	Given	Received
		RECOMMISSIONING			
		REMOVE ALL THE EARTHS			
	GRASLAND SUB	OPEN 11KV BLOEMSPRUIT OHL			
	MAARTENWEG	OPEN 11KV L/L10			
	KENDAL 147	OPEN VOORSPOED OHL			
	STASIE 172	OPEN VOORSPOED OHL			
	VOORSPOED	CLOSE G/L			
	ELITE	CLOSE A/R			
	ELITE DC	CLOSE 11KV CB 2			
	GRASLAND SUB	CLOSE 11KV BLOEMSPRUIT OHL			

ISOLATION ONLY	RECOMMISSIONING ONLY
TIME AND DATE STARTED	TIME AND DATE COMPLETED
...../...../...../20...../...../...../20.....
OPERATION CARRIED OUT BY	OPERATION CARRIED OUT BY
I HEREBY DECLARE THAT THE ABOVE MENTIONED INSTRUCTIONS WAS PERFORMED ACCORDINGLY	
IS THE MIMIC CHANGED ACCORDING TO THE OPERATION INSTRUCTIONS	IS THE MIMIC CHANGED ACCORDING TO THE OPERATION INSTRUCTIONS
YES / NO	YES / NO
PRINT NAME	PRINT NAME
SIGNATURE	SIGNATURE